

基隆市天外天垃圾資源回收(焚化)廠 無機廢水水質分析表

申報月份	採樣日期	項目	無機廢水														溫度	pH
			化學需氧量 COD	懸浮固體 SS	銀 Ag	銅 Cu	鋅 Zn	總鉻 Tot-Cr	六價鉻 Cr6+	溶解性鐵 Fe	溶解性錳 Mn	鉛 Pb	鎘 Cd	有機汞 Org-Hg	總汞 Tot-Hg	鎳 Ni		
			mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L		
偵測極限			2	1	0.009	0.023	0.013	0.022	0.0024	0.024	0.014	0.16	0.0076	-	0.000076	0.044	-	-
9601	2007/01/03	上旬	35	16.7	ND	0.05	0.08	ND	ND	ND	ND	ND	ND	ND	ND	ND	29.7	7.9
	2007/01/16	下旬	4.8	5.9	ND	ND	0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	29.8	7.6
9602	2007/02/01	上旬	5.2	ND	ND	ND	ND	ND	0.0032	0.41	ND	ND	ND	ND	ND	ND	30.7	7.6
	2007/02/09	下旬	5.6	7.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	29.7	7.5
9603	2007/03/01	上旬	ND	1.8	ND	ND	ND	ND	ND	0.04	ND	ND	ND	ND	0.0002	ND	30.4	7.8
	2007/03/19	下旬	2.9	2.2	ND	ND	ND	ND	0.022	0.38	ND	ND	ND	ND	0.0002	ND	29.8	8.6
9604	2007/04/02	上旬	ND	1.8	ND	ND	ND	ND	ND	0.04	ND	ND	ND	ND	0.0002	ND	30.4	7.8
	2007/04/17	下旬	ND	ND	ND	ND	ND	ND	0.0065	0.08	ND	ND	ND	ND	ND	ND	28.9	7.8
9605	2007/05/02	上旬	2.5	ND	ND	ND	ND	ND	ND	0.29	ND	ND	ND	ND	ND	ND	29.1	7.6
	2007/05/14	下旬	ND	1.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	28.8	7.4
9606	2007/06/01	上旬	14.3	ND	ND	ND	ND	ND	ND	0.08	ND	ND	ND	ND	0.0002	ND	29.5	7.8
	2007/06/14	下旬	ND	2.4	ND	ND	0.05	ND	0.01	0.31	ND	ND	0.008	ND	0.0003	ND	28.9	7.4
9607	2007/07/02	上旬	2.6	1.7	ND	ND	ND	ND	ND	0.16	ND	ND	ND	ND	0.0001	ND	29.9	7.7
	2007/07/16	下旬	4.4	2	ND	ND	ND	ND	ND	0.09	ND	ND	ND	ND	ND	ND	31.7	7.8
9608	2007/08/02	上旬	4.4	1.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	32.1	7.8
	2007/08/16	下旬	ND	2	ND	0.023	ND	ND	ND	0.03	ND	ND	ND	ND	0.0002	ND	30.4	7.7
9609	2007/09/06	上旬	ND	2.4	ND	ND	ND	ND	ND	0.11	ND	ND	ND	ND	0.0005	ND	30	7.7
	2007/09/17	下旬	ND	1.7	ND	ND	ND	ND	ND	0.03	ND	ND	ND	ND	ND	ND	29	7.7
9610	2007/10/01	上旬	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0001	ND	29.7	7.8
	2007/10/15	下旬	ND	1.6	ND	ND	0.04	ND	ND	0.12	ND	ND	ND	ND	ND	ND	25.7	7.6
9611	2007/11/02	上旬	4.9	2.4	ND	ND	0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	23.8	6.8
	2007/11/19	下旬	ND	ND	ND	ND	0.01	ND	ND	ND	ND	ND	ND	ND	ND	ND	25.8	7.6
9612	2007/12/03	上旬	ND	1.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	24.5	7.3
	2007/12/14	下旬	ND	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	23.4	7.5