

基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位:dB(A)	65	70	65	55	65	70	65	55
11001	45.8	48.5	45.6	43.9	45.4	48.2	46.5	44.5
11002	41.8	46.7	44.4	40.8	41.4	45.9	44.5	40
11003	47.3	48.3	41.1	45.7	46.8	48	41.6	43.3
11004	48	55.6	49.9	47.4	52.3	53.3	53.5	51.9
11005	47.2	57.3	53.1	49.7	49.3	53.7	52.7	45.7
11006	53.6	58.2	55.2	54.7	61.2	64.5	60.5	58.9
11007	54.7	54.6	60.2	51.7	54.7	51.6	50	52.2
11008	52.2	56.6	52.5	52.3	50.4	55.3	48.4	49.2
11009	50.4	56.6	51.9	50.4	52.4	54	49.9	52.9
11010	52.1	55.8	51.5	52.1	51.3	52.6	50.8	50.9
11011	45.1	51.7	49.4	46.9	51.8	51.7	50.9	51.2
11012	43.6	58.2	47.5	44.8	50.3	52.6	47.3	50.2